

**LA CANTINA DOORS**  
3270 Corporate View, Suite D  
Vista, CA 92081

Report No. : W06D-123  
Date : August 25, 2006  
Page : 1 of 1

**TESTING SUMMARY**

**SERIES:** LCD 3 Wood Bi-fold Door  
**CONFIGURATION:** Three (3) Left Bi-fold Out-swing panels with one (1) Right Out-swing panel  
**FRAME SIZE:** 147.31" x 99.56"

<b>TEST DESCRIPTION</b>	<b>MEASURED</b>	<b>ALLOWED</b>
Air Infiltration (ASTM E 283) 1.57 PSF	0.11 CFM/Ft <sup>2</sup>	0.3 CFM/Ft <sup>2</sup>
Water Penetration (ASTM E 547) 4.50 PSF	No Leakage	No Leakage
Uniform Load Deflection (ASTM E 330) 25.0 PSF POS 25.0 PSF NEG	0.851" 0.963"	No Damage No Damage
Uniform Load Structural (ASTM E 330) 37.5 PSF POS 37.5 PSF NEG	0.03" 0.05"	0.40" Set 0.40" Set

Testing Completed: August 14, 2006

  
Melchor Ordaz  
Test Dept. Manager